

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3550-0450:107 Page 1 of 1

CATEGORY: Door Closers/Holders/Releasing Devices

LISTEE: LCN Closers, 121 Railroad Avenue W., Princeton, IL 61356
Contact: *Ruth Gallianetti (815) 875-3311 Fax (815) 879-1495

DESIGN: Models 4040 SP and 4040 SDB door holder/closer. Model 4040 SDB employ an integral 9 V battery operated smoke detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions and applicable codes and ordinances. Authority having jurisdiction should be consulted prior to installation.

MARKING: Listee's name, model designation and UL label.

APPROVAL: Listed as door holder/closer for use on single swinging type fire door.

*Rev. 06-09-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 9, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager